



Fachausschuss Elektrotechnik
Gustav-Heinemann-Ufer 130

Prüf- und Zertifizierungsstelle
50968 Köln

Solutronic GmbH
Küferstraße 18
73257 Köngen

Ihr Zeichen:
Ihre Nachricht vom:
Unser Zeichen UB.010.17 PI/Ow
(bitte stets angeben):
Ansprechperson: Herr Pohl
Telefon: +49 221 3778-6301
Fax: +49 221 3778-6322
E-Mail: pohl.wolfgang@bgetf.de
Datum: 25.03.2008

Certificate of compliance 08009

Product: Automatic switching device (ENS)

Type: ENS

Normal use: Automatic switching device, inaccessible to the distribution system operator, serving as a safety interface between a distributed generation system and the low-voltage grid. Equivalent substitute for a switching device with isolating function accessible at all times to the distribution system operator.

The device is integral part of the grid-connected PV-converter type SOLPLUS 25 SOLPLUS 35, SOLPLUS 50, SOLPLUS 55..

Testing performed in accordance with:

DIN V VDE V 0126-1-1 (2006-02) "Automatic disconnection device between a generator and the public low-voltage grid"

This statement is based on the test-report (ISET e. V., Kassel) 2005-02-14.
The device fulfils the normative requirements of the above mentioned standard for the intended use.

The validity of the certificate of compliance shall cease no later than:

31 December 2013

- Martin Mehlem -
Head of the testing and certification body